RESPONSE TO PRE-BID QUERIES

S. No.	Query	Response		
1.	Transformer - Power Control Panel - Kindly provide the load calculation designs so that	The load distribution has already been calculated based on the project		
	the panel can be designed for Incoming & outgoing Loads Circuit Breakers etc	requirement. The details on panel design/ specification is being provided as part of the addendum to the tender document.		
2.	Rainwater Harvesting - Please provide the building design so that estimation can be done for bringing the rainwater through down pipes	Drawing is being provided as part of the addendum to the tende document.		
3.	Page 2 says last date of submission on 30 Aug; however page 6 says 23.08.2021. Please Clarify	30 th August 2021 is the last date of bid submission		
4.	Is Electric motor/ diesel Engine required for the chaff cutters	Yes		
5.	Incubation room dimension - Is there any layout, technical drawings. Does the PUF Insulated panel require Brick wall as well?	Spawn lab layout and drawing is being issued as addendum to the tender document.		
		Brick work is in the scope of work of contractor. Same is under implementation.		
6.	Transformer comes in 315 kva - is Copper wound or aluminium wound required. Also	Copper wound is required.		
	share step down of transformer would be from 33 KVA line or 11 KVA - Is transformer pad within scope of bidder? Who shall do the earthing	Step down transformer will be 11 KVA line.		
		Pole mounted transformer to be installed.		
7.	Powel Panel Can only be designed if the load distribution is available. Please share the details	The load distribution is being provided as part of the addendum to the tender document.		
8.	Is wiring between panel/DG/Transformer in scope of bidder? How about from Panel to various machines - If yes, please share all wiring/cabling details	Wiring b/w DG, transformer and panel is in the scope of work of the bidder.		
		However, all wiring from panel onwards to machines / sections etc is not in scope of work for transformer/ DG set supplier		
9.	DG set requires Earthing - Whose scope, is it? Is auto start/off feature required in DG	Yes, auto start/ off feature is required.		
		However, bidder may give its proposed design/ specification for consideration by the technical team justifying the utility and longevity of the proposed equipment.		

Snoter Rox Kayathikara

SECRETARY Mendipathar Multipurpo Go-op Society Ltd

ing

Lucayfrang la Morrie

10.	Rainwater Harvesting - Please share more details - Building layout Drawing from where will rain water be collected	Drawing is being shared as part of Addendum to the tender document.			
11.	Water Treatment and recycling plant - 100 m3 per day recycle system which consist of black & grey sewage - are they to be reused?	Only water from the cold pasteurization system is going to be reused. 80% of the treated water will be reused in the facility. 20% of the water			
12.	Water Treatment and recycling plant - 20m3 water discharge system - What kind of water are we talking of?	will be softened before it is discharged. The system must include complete mechanical filtration system for the 100 m3 water recycling			
13.	Water Treatment and recycling plant - 20m3 / day water softening plant - Will require water test report for effective design and quotation	system and all piping and installation.			
		Ground Water testing report is being provided as part of addendum to the tender document.			
14.	CCTV - requirement speaks of a computer - What is the purpose - Please share specifications for the same	Integrated computer system with suitable provision for the periodic (interval of one month) back up of data in DVD for Fixed camera – 16 channel system.			
		OR			
		In case the cameras have in-built pen drive system to take back up and recordings, then a separate computer system in not required.			
15.	CCTV - HD Space is not mentioned, is Power Back UP reqd, Monitor size not mentioned.	HD drive – as per system requirement.			
	if yes please share specs, Document speaks of remote connectivity. Provision for Internet should be made available at site	Yes, power back up required.			
		Yes, internet connectivity will be made available at site			
16.	CCTV - Placement of camera is not mentioned, hence would require drawings along with	Fixed – 240 degree (night vision) – bullet camera (weatherproof): 4 nos.			
	kind of wiring required (Naked, casing, concealed)	to be installed outside the facility including parking area.			
		Fixed – 240 degree (night vision) - doom camera: 12 nos. for inside the facility ie. Lab, bag section, Admin & account, dehydration & VA section,			
		Pre-processing area etc.			
17.	It would be great if you can share the detailed drawings along and layout for the bidder to place the quotes properly. Also group wise estimated cost would help us bid at the	Section wise plan is being issued as Addendum to the tender document.			
	right level	Group wise cost estimation is as under:			
		Group 1: Bag Making & Filling Section: INR 56.71 Lakh			
		Group 2 : Dehydration, Powder making & Packaging Section: INR 67.86 Lakh			
		Group 3: Spawn Lab Section: INR 89.75 Lakh			

Snoth Rox Kayathicara

SECRETARY Mendipathar Multipurpos Go-op Society Ltd

ijay

Luckyfrang le Mornin

		Group 4: Utilities Section: INR 29.01 Lakh		
18.	After sterilization in Autoclave wheat should be cooled by spreading on floor/ stretcher OR by mechanical cooling system. For which one unit is required to be addded. Mechanical cooling system should be accepted to avoid contamination by hand touch.	No separate cooling system is included in the current design. the cooling will be done through natural cooling process. In case you have a better solution please add it in your bid as additional suggested items. please explain the working of your suggested equipment and the advantage of using this system. Please also include the price of the product in the price bid as well in the category of additional suggested items but not to be included in the total price bid. This equipment will be separately evaluated based on technical and price parameters and may be purchased separately if budget permits.		
19.	In dehydration, packing section, in item No. 11, Tray dimension is given as 24"x18"10". Is there any typing mistake? Tray height always be max 2 to 4". Please confirm.	Specs amended. Depth for the Tray to be kept as 4"		
20.	Electric heater-based dehydration unit capacity is given as 500 kg per batch. If 500 kg mushroom is required to be accommodated at a time, drier will be very big wherein Air circulation will not be so good as a result of which drying time will be very long. Moreover, the size of the drier will be so big and it will be very difficult to transport and get entry into room.	You may give your proposed design for consideration by the technic		
21.	80 m2 (845 sq.ft) area is suggested for 500 kg mushroom, oyster mushroom should be distributed for better drying in an area @ 84 sq.ft for maximum 38 to 40 kg. Thus, in total area of 845 sq. ft or 80 sq. mtr, maximum 400 kg mushroom can be accommodated for better drying.	No change in specifications. Tray area requirement remains same. You may give your proposed design for consideration by the technicatem.		
22.	Biomass based cold storage requires electricity to be generated by Gasifier. Hence it is suggested to think about solar based cold storage although in Meghalaya which is cloud prone area, effectiveness of Solar may be difficult. Off grid or On grid solar system may be the solution to run cold storage apart from electricity.	No change in specifications. Cold room is biomass based. Solar based will not be considered.		
23.	Portable Field Straw Cutter operated by 3 Hp Diesel Engine can give a production of 50 kg per hour. Hence 5 Hp Diesel engine is not required.	No change in specifications. You may provide additional details of 3 HP system as additional suggested design for consideration by technical team.		
24.	7.5 Hp Motor Straw cutter is capable to cut dry straw @ 1000 to 1200 kg per hour. Hence, 10 Hp motor operated unit may not be required.	No change in specifications. You may provide additional details of 7.5 HP system as additional suggested design for consideration by technical team.		

Snoth Rox Kayathicara

SECRETARY Mendipathar Multipurpos Go-op Society Ltd

ijay



25.	 General Plat layout where the machine to be installed with total available area for each Group/Section. For positioning of processing machinery, since few machineries requires Foundations. For General idea of exhaust system 	Layout drawings (section wise) is being shared as part of the addendum to the tender document.	
26.	Firms registered with MSME; do they also need to submit the EMD	No. All MSEs and/ or firms registered with MSME are exempted from EMD. Only certificate of registration is required to be submitted along with the bids	
27.	What is payment mechanism?	Payment mechanism is part of the tender document detailed out in clause No. 16 of the tender document	
28.	What is the value of Performance Security that successful bidder will need to submit?	Performance security will be calculated @ 3% of the contract value the successful bidder. Same shall be submitted in form Bank Guarant form a Scheduled Commercial bank.	
29.	Do we need to submit the copies of Financial Bid also	No. Financial bid will only be submitted in original. However, Technical bid will be submitted in Original and Duplicate.	

Snoth Rox Kayathicara SECRETARY Mendipathar Multipurpos Go-op Society Ltd

ijay



Luckyfrang le Mornin

ADDENDUM NO. 1

LAYOUT DRAWINGS OF THE FACILITY SECTIO WISE

PROPOSED OVERALL SITE PLAN



Mendipathar Multipurp Go-op Society Ltd



Luckyfrang le Momin



SECRETARY Mendipathar Multipurpose Go-op Society Ltd



Luckyfreng a Momin









TRANSFORMER PANEL LOAD REQUIREMENT/ SPECIFICATIONS

SI No.	. DESCRIPTION		Qty
1	MAIN LT FEEDER PANEL		
	Supplying and installation of metal enclosed free standing floor readable mounted front operated cubical type switch gear panel suitable for OUTDOOR Type installation conforming to IS: 8623 (Part I & II). Panel should be made of sheet steel and thickness not less than 2mm and structural steel having light section with arrangement for sealing the covers and lockable doors. The panel shall be completely dust tight and vermin proof and shall be painted with anti-corrosive and anti-condensation type two coats of primer and two coats of paint conforming to Degree of Protection for enclosure shall be IP-55. All wiring shall be PVC insulated and PVC sheathed of 1100-volt grade of required size. The panel should have provision of entry of cable at the bottom and also provision of outgoing feeders from the bottom of the panel. The panel shall be incorporated with single copper busbarsystem. The bus bar shall be of high-quality copper of uniform cross section. The panel shall consist of the following items (viz. Voltmeter, Ammeter, CT, indicating lamps, selector switch etc.) connected as per drawing and shall be flush mounted on the front of the panel.	Set	1
	Incommer:		
a)	500 А ,4Р, МССВ, 36 КА	Nos	2
b)	500 A, 4P, on-load Changeover switch	Nos	1
c)	Digital Ammeter	Nos	2
d)	Digital Voltmeter	Nos	2
e)	CT 500/5	Sets	1
f)	CT 500	Sets	1
g)	Switch Fuse Unit	Nos	6
h)	Selector Switch	Nos	4
i)	LED Indicating Lamp	Sets	2
j)	Bus-Bars: 960 A TPN electrolytic Copper Bus Bar of uniform cross-section (60mmx10mm)	Sets	1
	Outgoing:		
k)	250 A 4P MCCB 36 KA	Nos	1
I)	40 A 4P MCCB 25 KA	Nos	1
m)	100 A 4P MCCB 25 KA	Nos	1
n)	63 A 4P MCCB 25 KA	Nos	1
o)	160 A 4P MCCB 25 KA	Nos	2
р)	40 A 4P MCB	Nos	2
2	Supply, Installation antistatic rubber mat suitable for 1.1 KV Voltage grade	Sq.M	2
3	Supply, Fitting Fixing of Shock Treatment Chart	Each	4

Snoter Rox Kayathikara

SECRETARY Mendipathar Multipurpose Go-op Society Ltd

iny

Luckyfrang le Mornin



GROUND WATER TEST REPORT

Snoten for Kayathikara

SECRETARY Mendipathar Multipurpose Go-op Society Ltd





SECRETARY Mendipathar Multipurpose George Society Ltd





Mendipathar Multipurpot Go-op Society Ltd

