



## MEGHALAYA BASIN MANAGEMENT AGENCY (MBMA)

Regd. Address: House No. L/ A-56 Lower Nongrim Hills,

Shillong, East Khasi Hills, Meghalaya- 793003

(CIN No. U75144ML2012NPL008509)

Phone: +91-364- 2522921/2522992

Website: [www.mbda.gov.in](http://www.mbda.gov.in), E-mail: [admin.mbda@gov.in](mailto:admin.mbda@gov.in)

No: PLN/MBMA/17837/2025/NF/04

Dated 15/01/2026

### Corrigendum 1

**Title of the Tender:** Request for Bid for Procurement of Office Furniture, Fixtures, IT and other equipment for establishment of CM Connect Centres at Blocks in Meghalaya.

**RFB Reference Number:** PLN/MBMA/17837/2025/NF/02, 20-12-2025

Sl No	Clause No/ Page No	Query/ Modification Requested/ Existing Clause	Remark/ Reason	MBMA's response/ Revised Clause
1	Section VII: Schedule of Technical Specifications of Goods, Page 18	Online UPS with Battery: <b>Phase:</b> Single Phase  <b>KVA - 3 KVA</b>  <b>Voltage Range:</b> 160-280VAC @100% Load & shall support up-to 110Vac for 50% load  <b>Backup Time:</b> Minimum 4 Hrs on 3KVA/3000KW Load <b>AH Required:</b> Minimum 300AH  <b>Certification Compliance -</b> CE/ROHS Certifications: BIS, ISO 9001, 14001,45001 <b>Warranty:</b> Minimum 2 Years Onsite for UPS and 3 Year for Batteries  <b>Other:</b> With Stand	NA	Online UPS with Battery: <b>Phase:</b> Single Phase <b>KVA - 3 KVA</b> <b>Voltage Range:</b> 160-280VAC @100% Load & shall support up-to 110Vac for 50% load <b>Backup Time:</b> Minimum 4 Hrs on 3KVA/3000KW Load <b>AH Required:</b> Minimum 14400 VAH Exide/Quanta/similar <b>Certification Compliance -</b> CE/ROHS Certifications: BIS, ISO 9001, 14001,45001 <b>Warranty:</b> Minimum 2 Years Onsite for UPS and 3 Year for Batteries <b>Other:</b> With Stand

(Executive Director)

Meghalaya Basin Management Agency